

□ G1998 Safety Station with WideArea™ Eye/Face Wash, PVC Construction with Stainless Steel Valves

Application: All-PVC combination WideArea[™] eye/face wash and shower safety station. Unit is constructed of PVC, PVCcoated components and stainless steel valves for superior corrosion resistance. Ideal for industrial environments where harsh acids or caustics are present. Eye/face wash features four GS-Plus[™] spray-type outlet heads that deliver a flood of water over a wide area of coverage for complete rinsing of eves and face.

Shower Head: 10" diameter orange ABS plastic with 20 GPM flow control.

Shower Valve: 1" IPS Type 316 stainless steel stay-open ball valve. Valve has stainless steel ball and PTFE seals. Furnished with stainless steel actuating arm and 29" stainless steel pull rod.

Spray Head Assembly: Four GS-Plus[™] spray heads. Each head has a "flip top" dust cover, internal flow control and filter to remove impurities from water flow.

Eye/Face Wash Bowl: 11-3/4" diameter orange ABS plastic.

Eye/Face Wash Valve: 1/2" IPS Type 316 stainless steel stayopen ball valve. Valve has stainless steel ball and PTFE seals.

Pipe And Fittings: Schedule 80 PVC.

Supply: 2" IPS socket weld top female inlet.

Waste: 2" IPS socket weld female outlet.

Sign: ANSI-compliant identification sign.

Quality Assurance: Valve and spray head assemblies are factory assembled and water tested prior to shipment.

Available Options

- **G6040** Thermostatic mixing valve precisely blends hot and cold water to deliver tepid water as required by ANSI Z358.1-2014. Refer to "Thermostatic Mixing Valves" section for complete technical and product selection information.
 - **GRN** Green ABS plastic shower head and bowl.



AP275-200 Electric flashing light and alarm horn unit for mounting on wall or vertical pipe. Light illuminates and horn sounds when eye/face wash or shower is activated. Furnished complete with flow switch and mounting hardware.

AP250-015 Modesty curtain for mounting on safety station.



Listed 8116. Units have been tested to and comply with

ANSI Z358.1-2014 and the


Uniform Plumbing Code.



312 447 8100 TELEPHONE gesafety.com



□ G1998 Safety Station with WideArea™ Eye/Face Wash, PVC Construction with Stainless Steel Valves



Sign Included



Due to continuing product improvement, the information contained in this document is subject to change without notice. All dimensions are \pm 1/4" (6mm). rev. 021023

THIS SPACE FOR ARCHITECT/ENGINEER APPROVAL

Guardian Equipment 1140 N North Branch St Chicago, IL 60642

312 447 8100 TELEPHONE 312 447 8101 FACSIMILE gesafety.com

Listed 8116. Units have been tested to and comply with ANSI Z358.1-2014 and the Uniform Plumbing Code.

